

Knauf Gips KG  
Am Bahnhof 7  
97346 Iphofen  
GERMANY

Eurofins Product Testing A/S  
Smedeskovvej 38  
8464 Galten  
Denmark

CustomerSupport@eurofins.com  
www.eurofins.com/VOC-testing

## VOC EMISSION TEST REPORT


### Indoor Air Comfort GOLD<sup>®</sup>

29 October 2021


## 1 Sample Information

Sample name	K466.de Knauf Fireboard-Spachtel
Batch no.	-
Stated production date	04/03/2021
Product type	Levelling compound
Sample reception	15/03/2021

## 2 Brief Evaluation of the Results

Regulation or protocol	Conclusion	Version of regulation or protocol
French VOC Regulation		Decree of March 2011 (DEVL1101903D) and Arrêté of April 2011 (DEVL1104875A) modified in February 2012 (DEVL1133129A)
French CMR components	Pass	Regulation of April and May 2009 (DEVP0908633A and DEVP0910046A)
Italian CAM Edilizia	Pass	Decree 11 October 2017 (GU n.259 del 6-11-2017)
ABG/AgBB	Pass	Ausschuss zur gesundheitlichen Bewertung von Bauprodukten (June 2021)
Belgian Regulation	Pass	Royal decree of May 2014 (C-2014/24239)
EMICODE	EC 1 PLUS	April 2020
Indoor Air Comfort <sup>®</sup>	Pass	Indoor Air Comfort 7.0 of May 2020
Indoor Air Comfort GOLD <sup>®</sup>	Pass	Indoor Air Comfort GOLD 7.0 of May 2020
Blue Angel (DE-UZ 113)	Pass	DE-UZ 113 for "Low-Emission Floor Covering Adhesives and other Installation Materials" (Version January 2019)
BREEAM International	Exemplary Level	BREEAM International New Construction v2.0 (2016)
BREEAM <sup>®</sup> NOR	Pass	BREEAM-NOR New Construction v1.2 (2019)

Full details based on the testing and direct comparison with limit values are available in the following pages  
Regarding pass/fail decision rule please see appendix



Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry