

CERTIFICATE

Number of certificate:	035-FIW-2-016.0-01
Holder of certificate:	Saint-Gobain Isover G+H AG Bürgermeister-Grünzweig-Str. 1 67059 Ludwigshafen am Rhein, Germany
Manufacturing plant:	SAINT-GOBAIN ISOVER G+H AG 51465 Bergisch-Gladbach, Germany
Product:	U TECH Pipe Section MT 4.0
Product description:	Pipe section made of mineral wool according to EN 14303:2009+A1:2013 (Technical properties see annex)
Technical specification of certificate holder:	Data sheet U TECH Pipe section MT 4.0 / Protect 1000 S (20.01.2022)
Designation code:	MW-EN14303-T8/9-ST(+)-660-WS1-CL10
AGI-destination code:	10.04.03.99.99
Certification Basis:	European INSULATION VDI and INSULATION KEYMARK Scheme for Thermal Insulation Products Revision: 2.1



035-FIW-2-016.0-01

This certificate entitles to use the above conformity mark in connection with the number of certificate. This certificate was first issued on 17.08.2020 and will remain valid as long as the factory production control requirements, the product, and the manufacturing conditions in the plant do not change significantly (but not longer than 09.12.2025).

Gräfelfing, 09.12.2024



A publication of extracts or a referring to the Certificate and its annex requires the prior written approval of FIW München. Certification body accredited by DAkkS according to DIN EN ISO/IEC 17065:2013. The accreditation is only valid for the scope of accreditation listed in the annex to the certificate D-ZE-14116-01-00.

ANNEX to CERTIFICATE

035-FIW-2-016.0-01

Product:	U TECH Pipe Section MT 4.0
Product description:	Pipe section made of mineral wool according to EN 14303:2009+A1:2013
Thickness range	020-120 [mm]

Certified properties:

Thermal conductivity:

Temperature °C	40	50	100	150	200	300	-	-
W/(m·K)	0,035	0,037	0,043	0,052	0,062	0,092	-	-



Maximum service temperature: 660 °C

Reaction to fire: A1L

Water soluble chlorides: ≤ 10 mg/kg

Short term water absorption: ≤ 1 kg/m²

Gräfelfing, 09.12.2024

Certification Body

Ralph Alberti


A publication of extracts or a referring to the Certificate and its annex requires the prior written approval of FIW München, Certification body accredited by DAkkS according to DIN EN ISO/IEC 17065:2013. The accreditation is only valid for the scope of accreditation listed in the annex to the certificate D-ZE-14116-01-00.